



# Landlord Gas Safety Record

Cert. No. 

Safety Inspection and reporting carried out in accordance with the Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure.

## Company / Installer

## Job Address

## Customer / Landlord

Engineer Martin Williams  
 Company North Somerset Gas Services Ltd  
 Address 11  
 Embercourt Drive  
 Backwell  
 Bristol  
 Post Code BS48 3HU  
 Tel No. 07944975650  
 Gas Safe Reg 191360  
 ID Card No. 4461190

Name  
 Address 27  
 Trendlewood Park  
 Bristol  
 Post Code  
 Tel. No

Name Mr M Owen  
 Company Mcgowan Investments  
 Address Catherine House  
 Harborough Road  
 Northants  
 Post Code NN6 9BX  
 Tel. No

## Appliance Details

## Inspection Details

No	Location	Appliance Type	Make	Model	Flue Type	Landlord's Appliance	Appliance Inspected	Operating Pressure (mbar)	Heat Input (kW/h)	High Combustion Reading			Low Combustion Reading			Safety device(s) correct operation	Ventilation Provision satisfactory	Visual condition of flue and termination satisfactory	Flue Performance test	Appliance Serviced	Appliance safe to use
										Ratio	CO ppm	CO2 %	Ratio	CO ppm	CO2 %						
1	Loft	Boiler	Vaillant	Thermocompact vc242eh	RS	Yes	Yes	20	31.70	0.0021	26	1.5	0.0015	26	1.6	Yes	Yes	Yes	Pass	No	Yes
2																					
3																					
4																					
5																					
6																					

## Defects / Identified

## Labels and Warning Notice Issued

## CO Alarm(s)

## Smoke Alarm(s)

1																					
2																					
3																					
4																					
5																					
6																					

CO Alarm(s) fitted   
 CO Alarm(s) tested and Satisfactory

Smoke Alarm(s) fitted   
 Smoke Alarm(s) tested and Satisfactory

Emergency Control Accessible Yes Gas Tightness Satisfactory Yes

Gas Installation Pipework Visual Inspection Satisfactory Yes

Equipotential Bonding Yes

NEXT INSPECTION DUE ON OR BEFORE 

## Comments

## Signatures

Issued by: Signed

Received Signed by:

Date

Print Name

Print Name