

Fire & Emergency Lighting Test Sheet



Date 21/02/2020

Job Clifton

Device No.	Device Type	Device Location	Pass	Fail
	Smoke Detector	Ground Floor Entrance	√	
	Call Point	Ground Floor Entrance	√	
	Smoke Detector	Lounge	√	
	Smoke Detector	Room 1	√	
	Smoke Detector	Room 2	√	
	Smoke Detector	Room 3	√	
	Smoke Detector	Room 4	√	
	Smoke Detector	Room 5	N/A	
	Smoke Detector	Room 6	N/A	
	Call Point	Kitchen	N/A	
	Heat Detector	Kitchen	√	
	Heat Detector	Boiler Cupboard	√	
	Smoke Detector	Hallway	√	

Sounder Test (Tick)
√

Battery Test (Tick)
N/A

Battery Size
2.1ah

Battery Date
Jan-19

Em Light No.	Emergency Light Location	Pass	Fail
	Ground Floor Entrance	√	
	Lounge Area	N/A	
	Stairwell	N/A	
	Kitchen	N/A	
	Hallway	√	

Name STEVE BAKER

Signature

Notes