



# Landlord Gas Safety Record

Cert. No. **North Somerset Gas Services Ltd**

Safety Inspection and reporting carried out in accordance with the Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure.

**Company / Installer**

Engineer   
 Company   
 Address   
  
  
  
 Post Code   
 Tel No.   
 Gas Safe Reg   
 ID Card No.

**Job Address**

Name   
 Address   
  
  
 Post Code   
 Tel. No

**Customer / Landlord**

Name   
 Company   
 Address   
  
  
 Post Code   
 Tel. No

**Appliance Details****Inspection Details**

	Location	Appliance Type	Make	Model	Flue Type	Landlord's Appliance	Appliance Inspected	Operating Pressure (mbar)	Heat Input (kW/h)	High Combustion Reading			Low Combustion Reading			Safety device(s) correct operation	Ventilation Provision satisfactory	Visual condition of flue and termination satisfactory	Flue Performance test	Appliance Serviced	Appliance safe to use
										Ratio	CO ppm	CO2 %	Ratio	CO ppm	CO2 %						
1	Compartment	Boiler	Vaillant	Ecotec Plus 618	RS	Yes	Visual	20	14	0.0007	64	9.5	0.0006	58	9.4	Yes	Yes	Yes	Pass	No	Yes
2																					
3																					
4																					
5																					
6																					

**Defects / Identified****Labels and Warning Notice Issued****CO Alarm(s)****Smoke Alarm(s)**

1																					
2																					
3																					
4																					
5																					
6																					

Labels and Warning Notice Issued

CO Alarm(s) fitted  Smoke Alarm(s) fitted

CO Alarm(s) tested and Satisfactory  Smoke Alarm(s) tested and Satisfactory

Emergency Control Accessible  Gas Tightness Satisfactory Gas Installation Pipework Visual Inspection Satisfactory Equipotential Bonding **NEXT INSPECTION DUE ON OR BEFORE** **Comments****Signatures**

Issued by: Signed   
 Print Name

Received Signed   
 by:   
 Print Name

Date